

Mr T. Adlington
Elster Metering Systems Ltd
Unit 1 Toll Gate Park
Beaconsfield Road
Stafford
Staffordshire
ST16 3HS

Our Reference EMA 121661
E_mail: Rae.Jackson@SGS.com
Date : 23 March 2009

Dear Mr Adlington

Manufacturer: Elster Metering Systems.

Description of Meter :- Single-phase Direct connected Credit Import/Export, Active/Reactive, Multi-Rate, Electricity Meter

This letter confirms that the manufactured design and specimens provided have been examined and based on the results of type approval examination and tests it is considered that the Meter conforms to the requirements of :-

EC Directive 2004/22/EC EN 50470 2006 parts 1 & 3

IEC 62052-11: 2003, Electricity metering equipment (AC) - General requirements, tests and test conditions. Part 11: metering equipment.

IEC 62053-21: 2003, Electricity metering equipment (AC) - Particular requirements. Part 21: Static meters for active energy (classes 1 & 2)

IEC 62053-23: 2003, Electricity metering equipment (AC) - Particular requirements. Part 23: Static meters for reactive energy (classes 2 & 3)

Confirmation based on type examination reports:

EMA 121661 dated 24th October (EN 50470 2006 parts 1 and 3)

EMA 121661 dated 24th October (IEC 62053-23 2003)

EMA 121661 dated 24th October (IEC 62053-21 2003)



Rae Jackson
Head of Electricity Metering